



Winston H. Hickox
Secretary for
Environmental
Protection

Air Resources Board

Alan C. Lloyd, Ph.D.
Chairman

2020 L Street • P.O. Box 2815 • Sacramento, California 95812 • www.arb.ca.gov



Gray Davis
Governor

August 5, 1999

Jose E. Rodriguez
EMCO Wheaton Retail
1666 Yale Street
Chula Vista, CA 91913

99-8

Dear Mr. Rodriguez:

Emco Wheaton A1100 Overfill Prevention Valve

You requested California Air Resources Board (CARB) certification of the Emco Wheaton A1100 Overfill Prevention Valve for vapor recovery systems. This design is identical to the valve certified in Approval Letter 95-9 and 95-9-A except for the manufacturing process used. The original valve body was sand cast and this version is die cast.

As required by the Certification Procedures for Gasoline Vapor Recovery Systems at Service Stations, the approvals of the three State agencies are a precondition to certification by the Air Resources Board. The appropriate letters of approval have been received.

I find that the use of the Emco Wheaton A1100 Overfill Prevention Valve, when installed in accordance with the manufacturer's instructions and the conditions listed above, will not adversely affect the performance of vapor recovery systems on which it is installed. Therefore, the Emco Wheaton A1100 Overfill Prevention Valve is certified for use with CARB certified Phase I vapor recovery systems.

If you have any questions or wish to discuss this matter further, please call Joe Guerrero at (916) 324-7343 or Laura McKinney at (916) 327-1525.

Sincerely,

INTERNET VERSION

James J. Morgester, Chief
Compliance Division

cc:

Mr. Jim Johnston, Chairman,
CAPCOA Vapor Recovery Committee